



Cherokee County Fire & Emergency Services

Fire Marshal's Office

1130 Bluffs Parkway, Canton GA 30114
Phone: (678) 493-6290 Fax: (678) 493-6111

Final Plat Inspection Requirements

A final plat inspection has been requested.

The following must be completed in order to receive approval:

1. Road must have an approved surface.
2. Fire hydrants must be operational (have a water flow)
3. Hydrants facing the correct direction
4. Street signs must be in, permanent or temporary weatherproof.
5. "Dead end streets over 150' must have approved FD turnaround"

This list is not all inclusive.

We will be inspecting the property according to the approved site plan.

You can also visit our website for further details

http://www.cherokeefmo.info/index.php?option=com_content&view=category&layout=blog&id=49&Itemid=89

If the inspection fails there will be a \$100.00 reinspection fee.

The property will not be inspected unless an email response is received.