



Cherokee County Fire & Emergency Services
Fire Marshal's Office

1130 Bluffs Parkway, Canton GA 30114
Phone: (678) 493-6290 Fax: (678) 493-6111

Final Plat Fire Department Certification Statement
Final Plat Inspection Requirements

In order to receive a final plat approval, the following must be completed:

1. Road must have an approved all weather surface.
2. Fire hydrants must be operational (have a water flow)
3. Hydrants facing the correct direction
4. Street signs must be in, permanent or temporary weatherproof.
5. "Dead end streets over 150' must have approved FD turnaround"

This list is not all inclusive.

We will be inspecting the property according to the approved site plan.

You can also visit our website for further details

http://www.cherokeefmo.info/index.php?option=com_content&view=category&layout=blog&id=49&Itemid=89

If the inspection fails there will be a \$100.00 reinspection fee.

The property will not be inspected unless an email response is received.