



# Cherokee County Fire & Emergency Services

150 Chattin Drive, Canton GA 30115

Phone: (678) 493-4000 Fax: (678) 493-4034

---

## Letter of Intent for use of a Structure

Name: \_\_\_\_\_

Address: \_\_\_\_\_

City/State: : \_\_\_\_\_

Cityview Number: : \_\_\_\_\_

Commercial or Residential Use: \_\_\_\_\_

The purpose of this letter is to determine if the structure will be used for commercial or residential. If the use is commercial, the building will fall under the review of the Cherokee County Fire Marshal's Office. If the use is residential, the Cherokee County Fire Marshal's Office does not review the plans.

If this building is to have the general public in the building, then the building will be considered commercial.

If in the future the use changes from residential to commercial you be required to comply will all commercial requirements.

- a. The following items will be required for a commercial building:
  - i. A fire hydrant within 300 feet from all parts of an unsprinklered building.
  - ii. A fire hydrant within 500 feet from all parts of a sprinklered building.
  - iii. All adopted codes by the Cherokee County Fire Marshal's Office.
  - iv. Turning radius that complies with all applicable codes for all interior and exterior turning radius.
  - v. A minimum of 24-foot parking lot driveway width, if the elevation of any structures exceeds 30 feet, then the driveway width must be a minimum of 26 feet.
  - vi. The fire department turnaround must be designed at a minimum to the 2012 International Fire Code Appendix D.
  - vii. The fire department access road must be designed as per the 2012 International Fire Code

By typing your name below you are confirming the use of the building.

This form must be emailed back to [Daniel Baiamonte](mailto:djbaiamonte@cherokeega.com)(click on Daniel) or email djbaiamonte@cherokeega.com to continue your building permit process.

Name: \_\_\_\_\_

Date: \_\_\_\_\_